



NOTES:

1. CURB & GUTTER SHALL HAVE A TOOLED CONTRACTION JOINT EVERY 10' AND BE SCORED A MIN. DEPTH OF $\frac{3}{4}$ "
2. CURB & GUTTER AND SIDEWALK SHALL HAVE $\frac{1}{2}$ " EXPANSION JOINT AT PC's, D.T's , CURB TURNS AND EVERY 100' ON STRAIGHT STRETCHES.
3. SIDEWALK SHALL HAVE A TOOLED CONTRACTION JOINT EVERY 5' AND BE SCORED A MIN. DEPTH OF $\frac{3}{4}$ ".
4. ALL CONCRETE POURED INSIDE CITY R.O.W. SHALL BE MINIMUM 6.5 SACK AND 4000 PSI MIX DESIGN AND THE ENTRAINED AIR CONTENT SHALL BE $\geq 5\%$ AND $\leq 8\%$.
5. PLACE AND COMPACT TO 95% STANDARD PROCTOR GRAVEL BASE COURSE AS REQUIRED IN SPECIFICATIONS
6. REMOVAL OF EXISTING SIDEWALK SHALL BE VIA A CLEAN SAWCUT.
7. ACI CERTIFICATION IS REQUIRED FOR PLACING AND FINISHING CONCRETE IN THE RIGHT-OF-WAY.

CURB AND SIDEWALK SECTION