



NOTE : ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING AND TOP SECTION, AND AROUND SEWER PIPE INTO MANHOLE SHALL BE WATERTIGHT.
 FOR CONNECTION TO NEW MANHOLES USE PSX OR EQUIVALENT GASKET AT ALL PIPE PENETRATIONS.
 FOR CONNECTIONS TO EXISTING MANHOLES USE WATERSTOP.
 MANHOLE CONSTRUCTION TO ADHERE TO ASTM C-478.
 ANY INLET DROP GREATER THAN 2.0' SHALL HAVE AN EXTERIOR INLET DROP INSTALLED.

STANDARD SANITARY SEWER MANHOLE (AND DROP INLET MH)