

ADDENDUM NO. 1
PARKS AND RECREATION FUEL STATION O.F. 1755.0
October 2, 2020

Bid Time and Date: 3:00 p.m., October 21, 2020
in the Rainbow Conference Room at the Great Falls Civic Center.

NOTICE TO ALL BIDDERS

The Contract Specifications and plans are hereby modified as follows, and in submitting his/her bid, each bidder shall acknowledge receipt of all addenda, which will become part of the Contract Documents according to the requirements outlined in the CONTRACT DOCUMENTS.

This addendum consists of two (2) pages.

CHANGES TO THE PROJECT MANUAL:

SECTION 17200 – FUELMASTER ® PLUS ADVANCED FUEL MANAGEMENT SYSTEM

PART 2—PRODUCTS

ADD


2.3 COMMUNICATION CABLE

- A. The communication cable for the Fuelmaster management system shall be a Duplex Singlemode 8.3/125 Fiber Cable, meeting the following specifications:
1. Manufactured from 8.3/125 duplex (zipcord) fiber PVC jacket.
 2. Connectors: 2 LC and 2 LC connectors on each end.
 3. Insertion loss testing performed on every connector (0.2db typical) and provided with cable.
 4. Fiber made from glass (not a polymer).
 5. Fiber optic distributed data interface (FDDI) and OFNR (riser rated)
- B. Fiber to Ethernet Adapter meeting the following specifications:
1. Optical Port: 1.25Gbps, 1310nm wavelength, Dual LC fiber, support Gigabit Ethernet
 2. RJ45 Port: UTP CAT5 10M/100M/1000M, Full Duplex or Half Duplex;
 3. Supports MDI/MDI-X auto crossover.
 4. Complies with IEEE 802.3/802.3u/802.3z/802.3ab

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The bidder shall acknowledge receipt of Addendum No.1 on the Proposal Form, and on the outside of the bid envelope, and include this Addendum with the Bid.

Issued By:
City of Great Falls
Engineering Department



Russell J. Brewer, P.E.
Project Engineer



END OF ADDENDUM No. 1