

ADDENDUM NO. 3
PARKS AND RECREATION FUEL STATION O.F. 1755.0

October 16, 2020

Bid Time and Date: 3:00 p.m., October 21, 2020
in the Rainbow Conference Room at the Great Falls Civic Center.

NOTICE TO ALL BIDDERS

The Contract Specifications and plans are hereby modified as follows, and in submitting his/her bid, each bidder shall acknowledge receipt of all addenda, which will become part of the Contract Documents according to the requirements outlined in the CONTRACT DOCUMENTS.

This addendum consists of one (1) page.

CHANGES TO THE PROJECT MANUAL:

TECHNICAL SPECIFICATIONS

SECTION 17000 – FIRE-RATED ABOVE GROUND FUEL STORAGE TANK

Revise the following sections to read

2.3 PIPING

- D. Aboveground piping shall be adequately supported and be protected from physical damage caused by freezing, frost heaving and vehicular traffic. **Piping shall be painted to aid in resisting corrosion.**


2.4 CONCRETE SUPPORT SLAB AND FOUNDATION

- D. Impact barriers shall be incorporated into the concrete slab design and shall meet all applicable fire, building and design codes. **Impact barriers shall be painted yellow to aid in resisting corrosion.**

ACKNOWLEDGEMENT OF ADDENDUM NO. 1

The bidder shall acknowledge receipt of Addendum No.1 on the Proposal Form, and on the outside of the bid envelope, and include this Addendum with the Bid.

Issued By:
City of Great Falls Engineering Department



Russell J. Brewer, P.E., Project Engineer

END OF ADDENDUM No. 1

