

ADDENDUM NO. 2

VALERIA WAY STORM DRAIN LINING (O.F. 1463.2)

February 28, 2023

Bids received at Office of City Clerk, Rm 104, Civic Center, P.O. Box 5021, #2 Park Drive South, Great Falls, Montana 59403, until 10:30 a.m. MST on **March 8, 2023**

NOTICE TO ALL BIDDERS

The Contract Specifications and plans are hereby modified as follows, and in submitting his/her bid, each bidder shall acknowledge receipt of all addenda, which will become part of the Contract Documents according to the requirements outlined in the CONTRACT DOCUMENTS.

This addendum consists of two (2) pages.

CLARIFICATIONS & QUESTIONS:

- I. Do you have manhole depths for these storm pipes? *Yes. Manhole depths are approximate See Table 1.*

Table 1	
Manhole ID#	Depth (ft.)
1351	7.8
66	11.7
67	10.9
3284	14.2
68	11.1
64	11.8
65	11.6
3281	13.4
16	14.1
20	12.8
21	14.9
24	13.4

ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The bidder shall acknowledge receipt of Addendum No.2 on the bid form, and include this Addendum with the Bid.

Issued By:
City of Great Falls, Engineering Department



Ryan Shaneybrook, Project Engineer

END OF ADDENDUM No. 2