

ADDENDUM NO. 2
SANITARY SEWER TRENCHLESS REHABILITATION PHASE 25 O. F. 1675.8
February 27, 2023

Bid Time and Date: 10:00 a.m., **March 8, 2023.**

City Clerk at the Finance Office Window, Room 104, Civic Center, P.O. Box 5021, #2 Park
Drive, Great Falls, Montana 59401

NOTICE TO ALL BIDDERS

The Contract Specifications and plans are hereby modified as follows, and in submitting his/her bid, each bidder shall acknowledge receipt of all addenda, which will become part of the Contract Documents according to the requirements outlined in the CONTRACT DOCUMENTS.

This addendum consists of one (1) page, and three (3) attachments. pages total.

CLARIFICATION:

A Right-of-way application will be required for work within the right-of-way.

The Contractor will be responsible for working with MDT for work within their right-of-way.

If overtime or work outside of normal working hours is required, due to no fault of the contractor, overtime rates may be waived.

UV cured lining will not be accepted on this project.

The flow for Line 1928 is approximately 100GPM peak flow. There are approximately 45 homes that feed into this line. Exact measurements could not be taken in time for this addendum.

BOND FORMS:

Add attached Bonds to the Project Manual

ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The bidder shall acknowledge receipt of Addendum No.2 on the bid form, and include this Addendum with the Bid.

Issued By:

City of Great Falls, Engineering Department

Amanda Brownlee, P.E., Project Engineer

END OF ADDENDUM No. 2