



600 2<sup>nd</sup> Street South  
Great Falls, Montana 59405  
406-452-3826

**ADDENDUM 1:**

**Date: August 11, 2023**

**Project:** City of Great Falls Public Works Generator Addition  
**FMS Project Number:** E23-COGF-005  
**Owner/User:** City of Great Falls, Public Works  
**Engineer:** FMS, Allen V. Meadors, PE, 600 2<sup>nd</sup> Street South, Great Falls, MT 59405  
**Attention:** All Bidders-Plan Holders  
**Pages:** 2 (Including Attachments)  
**Attachments:** None

Acknowledge receipt of this Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents and modifies them as noted below. All other aspects of the Contract Documents remain in effect.

**General Clarifications**

- Contractor shall have utility locates done to ensure existing utilities are not disturbed or damaged. Any damages done due to contractors work shall be repaired to like new by contractor at contractors cost.
- Top of generator pad shall be 6" above finish grade.
- PVC Conduit elbows below grade shall be concrete encased as specified.

**Drawings**

**Sheet E3.00B** - Added bollards for electrical service protection.



600 2<sup>nd</sup> Street South  
Great Falls, Montana 59405  
406-452-3826

**Specifications**

Replace/modify paragraphs below with text as shown.

**26 32 13 1.01 C.**

Source Limitations: Furnish engine generator sets and associated components and accessories produced by a single manufacturer and obtained from a single supplier. ***Generator manufacturer shall have a local maintenance facility (in Great Falls), and personnel capable of responding within 2 hours or less.***

**26 32 13 2.03 I.**

Contractor to include all fuel necessary for testing and training. ***After successful testing and training contractor shall fill tank with fuel.***

**26 32 2.07 C. 1.**

Provide on-site response within **2** hours of notification.